



PM RESOURCES LLC
YOUR PROJECT MANAGEMENT RESOURCE COMPANY

Design – Build Services
for
Westbrook Middle School HVAC Project
Addendum No. 4
April 5, 2017

Question: Who is the roofing manufacturer and installer?

Answer: The manufacturer is Firestone and the Contractor is Silktown Roofing

Question: What is the expected degree range for cooling?

Answer: The design standard should not exceed 76 degrees

Question: What area of the second-floor J wing should be included in the scope of work?

Answer: SPED J223, SPED 231, SPED J227(including Timeout Room), Classrooms J224, J225, J228, J229, J230, J232, J233, J234, J220, J221, J,222