

The Westbrook Health Department in collaboration with the Westbrook Water Pollution Control Commission would like to bring to your attention a revision to the Department of Public Health's Technical Standards for Subsurface Sewage Disposal Systems. As of January 2015 the following requirements took effect:



* Secondary Safety Lid

* **Septic tank, pump chamber, holding tanks and grease interceptor tank covers** shall be kept on the tank when riser assemblies are utilized, and in no case shall a cover be left off a tank when the riser cover weighs less than 59 pounds unless a secondary safety lid or device is provided below the riser cover.

* Retroactive requirement





*Secondary Safety Lid

